Physical and Chemical Research Center of Science and Environmental Analysis

Test Report

Report Number

(2014) 050708

Customer CHANGZHOU YONGFENG PACKING MATERIALS CO, LTD

Test Category Authorized

IIC

Test Item



Report Date: May 7,2014

Note:

- 1. The report is invalid without the special print of the analysis report and the ratifier's signature.
- 2. If the client has any questions about the test result, the client shall provide written notice, original analysis report and retest free to the testing center within fifteen days from the day of analysis report finished.
- 3. After the client finishes the procedure mentioned above, the testing center shall arrange the retest as soon as possible. If the retest result accords with client's dissent, the testing center shall refund all test and retest fees, otherwise, the client shall pay the retest charge.
- 4. The unrepeatable test shall not be retested. The client shall give up the right of dissent.
- 5. The test report issued is only responsible for the samples and does not express any opinions upon the lot from which the samples were drawn. The testing center shall have no legal responsibility and liability for any direct and indirect loss, damage or expense arising from the use of the analysis result.
- 6. The testing center is entitled to dispose the sample after finishing the sample test.
- 7. The testing center is supposed to assure objectivity and equity of the test and keep the client's commercial information, technique document, and analysis report secret.

Test Report Unit Address: No500 Cao Bao road Xu Hui District Shanghai Code: 200235 Tel: 400-888-1026 Web Address:www.huanjing315.com Email: test.315@ 163.com

Physical and Chemical Research Center of Science and Environmental Analysis (TEST REPORT)

Report Numb	er: (2014) 050708	4) 050708 page 1 of 2		
Sample	1.5mm high density EVA foam (60℃)	Specification	4mm / 6.5mm	
Quantity	15M²	Trademark	/	
Authorization Time	5/7/2012	Finished Date	5/ 17/2014	
Company	CHANGZHOU YONGFENG PACKING MATERIALS CO,,LTD			
Authorize Person	Miss zhou	Telephone	18017260921	
Test item	ПС			
Method	ASTM E492			
Installation	SPC Flooring over EVA(60) Underlayment on 6 inch (152mm) Concrete Slap Floor-Ceiling Assembly with Suspended Gypsum board Ceiling.			
Please see page 2 Conclusion		2		
	Issued Date: May 18, 2014			
Tester E	Checker 陈安红	Tech	nique control	

Physical and Chemical Research Center of Science and Environmental Analysis (TEST REPORT)

	Report Number: (2014) 050708 page 2 of 2			
Result					
1	Sample	Test item	Data		
1	1.5mm high density EVA foam (60℃)	IIC	72dB		
	ate :8/5/2014				
Size; 1:					
	rature (°C):25				
	re: Concrete Condominiums height: 2.8M				
	ickness: 240mm				
	and Windows state: Closed				
	1 6 (4.4.4.				
···En	d of report***				