

Requested by:	GAMBINI GROUP S.p.A. Via Radici in Piano, 675 – 41049 SASSUOLO (MO)		
For the sample:	Glazed ceramic tiles 35,5 x 71 x 0,9 cm marked "Articolo MARMI LATINA CREMA 35,5x71 cm".		
On (date): 27/12/17	Date of receipt in laboratory (sample delivered by the client): 12/12/17		
Test date	From: 10/01/18	To: 12/01/18	

EN ISO 10545-3 Determination of water absorption by boiling method

Water absorption (%) of each individual tile:

Test specimens	1	2	3	4	5
E (b)	0,12	0,11	0,14	0,10	0,10

E (b) average (%):

0,12

Eng. Giordana Carani
Technical approval



Prof. Maria Chiara Bignozzi
Director



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.